



Document Control Number:
ACE-J23-35BG0108-P4-0028

| | | | | | |
|---|-------------------|--|---------------|---|--|
| Client, Project and Location | | Project Note | | Delivery Order/Task Order TO 0001 | |
| USACE New Bedford Resident Office | | | | Project No. 35BG0108 | |
| New Bedford Harbor Superfund Site | | | | | |
| New Bedford, Massachusetts USACE Contract Number DACW33-03-D-0006 | | Note No.: 130 | | | |
| Confirmation of | | Date Held | 0207/07 | | |
| <input type="checkbox"/> | Project note-P1 | Location | Various | | |
| <input checked="" type="checkbox"/> | Client Meeting-P4 | Date Issued | 02/07/07 | | |
| <input type="checkbox"/> | Other | Recorded By | Mike Anderson | | |
| Subject | | Issued By | Mike Anderson | | |
| New Bedford Harbor – Client Update Meeting | |  | | | |
| | | Jacobs Project Manager | | | |
| Participants (* Denotes Part Time Participation) | | | | | |
| <u>Client</u> | <u>EPA</u> | <u>Jacobs/SES – NB Boston</u> | <u>Others</u> | | |
| Mark Anderson | Jim Brown | Mark Gouveia | Jim Atkins | Lisa Lefkovitz | |
| Paul L'Heureux | Dave Dickerson | Mike Anderson | Carl Wilson | Joe Coyne | |
| Gary Morin | Dave Peterson | Jerry Castiglione | | | |
| | | | | | |
| Item | Remarks | | | Action Required By | |

| | | |
|-----|--|--|
| 3.0 | AEROVOX | |
| | <ul style="list-style-type: none"> The group discussed safety concerns within Aerovox especially within the boiler room and cardboard box room. There are out of plumb columns, sagging ceilings, and cracks in masonry walls. The areas will be cordoned off. Also, a warning was issued against being inside the building when there are high winds or a significant snow load on the roof. | |

